

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 03

Dated: 29.05.2026

It is certified that an inspection team headed by J.E. Kateya

(Name of Officers with designation) from Junior Engineer PHED

inspected the Arya Public School, Pansidhmat, Gaur, Kateya Gop (841437)

(Name & Address of the school) on 27.05.26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. S.C.P. 25-26.03 dated 29/05/2026

of D.L.W.T. Laboratory, Gopalganj (PHED Lab) certified that

the Arya Public School, Pansidhmat (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6th month.

Signature with Seal: [Signature]
Name: Executive Engineer
Designation: PH Division, Gopalganj
Name & Address of the Office / Department: [Address]

To Arya Public School, Pansidhmat,
Gaur, Kateya Gop (841437)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature] 29/05/26
JE KATEYA

[Signature] 29.05.26
Lab. Panchetam

**Government of Bihar
Public Health Engineering Department
Water Quality Test Report**

District Name: Gopalganj

Division Name: P.H.Division Gopalganj

Sample code GpJ_25-26 03

Sl. No.	Block	Panchayat	Village	Ward No.	Location of Source	Parameters														Date of Testing	Remarks
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)	Total Coll		
1	Kateya	Bheriya	Parsidhnath	15	Arya Public School Gaura	7.81	0.1	554	360	170	44	18	25	210	0.36	0.51	254	0.04	Absent	29.05.2026	
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**		

[Signature]
Chemist / Lab Asst
DLL, P.H. Division, Gopalganj

[Signature]
AE
P.H.Division, Gopalganj / Bhora

[Signature]
Executive Engineer
P.H.Division, Gopalganj